



DETAIL
PANEL TRIM
DOOR-IN-DOOR TYPE
SCALE: NONE

- NOTES:**
- 1. CABINET CONSTRUCTION: ANSI GRAY FINISH, 14 -12 GAUGE WITH "U.L." LABEL
 - 2. ALL NAME PLATES SHALL BE PHENOLIC WITH ADHESIVE BACK.
(SEE NAMEPLATE SCHEDULE FOR DETAILS)
 - 3. REFER TO SPECIFICATIONS FOR APPROVED MANUFACTURERS.

NAME PLATE SCHEDULE			
ITEM NO	NAMEPLATE INSCRIPTION LINE 1 / LINE 2 / LINE 3 / LINE 4 / LINE 5	CHARACTER HEIGHT / BACKGROUND	REMARKS
1	PANEL B2 - E2 - 38G (OLD EX-15) / 225A 208Y/120V 3Ø 4WSN / FED FROM PANEL B2 - E2 - 30G/1, 3, 5	5/8" H WHITE CHAR. ON BLACK BACKGROUND	RED BACKGROUND FOR EMERGENCY POWER
2	VOLTAGE - 208Y/120V 3Ø 4WSN / AØ - BLACK / BØ - RED / CØ - BLUE / N - WHITE	1/4" H WHITE CHAR. ON BLACK BACKGROUND	
3	FOR PANEL ACCESS CALL / ACC: (206) 787-5406 OR / SHOP: (206) 787-5311	1/4" H WHITE CHAR. ON BLACK BACKGROUND	
4	WARNING - ANY UNAUTHORIZED USE OF / PANEL MAY RESULT IN SUSPENSION / OF PORT OF SEATTLE BADGE	1/2" H RED CHAR. ON WHITE BACKGROUND	5/8" H RED CHAR. FOR "WARNING" ONLY

R E V I S I O N S				<div>PROJECT MANAGER: — PROJECT ENGINEER: — DESIGN ENGINEER: — DRAFTER: — SCALE: AS NOTED DATE: — CHECKED/APPROVED BY: —</div>		<div><div>Port of Seattle</div><div>SEA-TAC INTERNATIONAL AIRPORT</div><div>PROJECT: F&I STANDARD DETAILS</div><div>SHEET TITLE: PANEL TRIM DOOR-IN-DOOR TYPE</div></div>		WORK PROJECT NO.	
NO.	DATE	BY	DESCRIPTION					CONSULTANT'S NO.	
1	03/01/2019	KDM	2019 F&I STANDARD DETAILS					262416 02	
2	03/01/2020	KDM	2020 F&I STANDARD DETAILS						