

6"

4"

!

WARNING

Arc Flash and Shock Hazard

Appropriate PPE Required

7' - 4"	Flash Hazard Boundary
12.3	cal/cm2 Flash Hazard at 18.0 Inches
	PPE Level
	Refer to NFPA 70E-2018 Table 130.5(G)
22.878	Fault Current (kA)
0.48	kV Shock Hazard when cover is removed
3' - 6"	Limited Approach
1' - 0"	Restricted Approach - Class 00 Voltage Gloves

Equipment Name: [EQUIP NAME] (Fed by: [UPSTREAM EQUIP])
[CONSULTANT], 1/23/2020, POS: _____

FONT STYLE: ARIAL

FONT SIZE: 47pt

FONT SIZE: 16pt

FONT SIZE: 9pt

FONT SIZE: 9pt

FONT SIZE: 9pt

EASYPower LABEL TEMPLATE AVAILABLE UPON REQUEST FROM F&I.

R E V I S I O N S				<div>PROJECT MANAGER: — PROJECT ENGINEER: — DESIGN ENGINEER: — DRAFTER: — SCALE: NONE DATE: — CHECKED/APPROVED BY: —</div>		<div>Port of Seattle SEA-TAC INTERNATIONAL AIRPORT</div> <div>PROJECT: F&I STANDARD DETAILS</div> <div>SHEET TITLE: ARC FLASH LABEL TEMPLATE</div>		WORK PROJECT NO.	
NO.	DATE	BY	DESCRIPTION					CONSULTANT'S NO.	
1	03/01/2019	KDM	2019 F&I STANDARD DETAILS					26057301	
2	03/01/2020	KDM	2020 F&I STANDARD DETAILS						